

PRODUCT SURVEILLANCE CERTIFICATE

Certificate No.:
109449-2012-CE-ITA-ACCREDIA

Initial date:
29 December, 2011

Valid:
15 April, 2018 – 14 April, 2021

This certificate consists of 2 pages

This is to certify that the final assessment process of

VALVOROBICA INDUSTRIALE S.p.A

Via Giovanni Falcone, 2 – 24050 Zanica BG- Italy

has been monitored and found to comply with respect to the conformity assessment procedure described in

ANNEX III MODULE C2 OF DIRECTIVE 2014/68/EU ON PRESSURE EQUIPMENT

The certificate is valid for the following scope:

Type of Pressure Equipment	Pressure Accessory
Product Name	Butterfly valves

Place and date:
Vimercate 12 February, 2018



SGQ N° 003 A	EMAS N° 009 P
SGA N° 003 D	PRD N° 003 B
SGE N° 007 M	PRS N° 094 C
SCR N° 004 F	SSI N° 002 G

Membro di MLA EA per gli schemi di accreditamento SGQ, SGA, PRD, PRS, ISP, GHG, LAB e LAT, di MLA IAF per gli schemi di accreditamento SGQ, SGA, SSI, FSM e PRD e di MRA ILAC per gli schemi di accreditamento LAB, MED, LAT e ISP

For the notified body 0496:
**DNV GL Business Assurance Italia
S.r.l.**

Nicola Privato
Management Representative

Certificate No.: 109449-2012-CE-ITA-ACCREDIA
 Place and date: Vimercate 12 February, 2018
 Revision No.: 02

Jurisdiction

Application of Directive 2014/68/EU and Decreto Legislativo n. 26 of 15 February 2016

Certificate history

Revision	Description	Issued date
00	Original certificate	29 December, 2011
01	Certificate renewal	24 April, 2015
02	Certificate renewal	12 February, 2018

EU-Type examination certificate reference

Certificate No.	Revision No.	Expiry date	Issued by Notified Body No.	Report No. (if NoBo 0496)
109448-2012-CE-ITA-ACCREDIA (Module B)	0-Original certificate	29 December, 2021	0496	85950096-9032011

Products covered by this certificate

Product name	Product description	Pressure rating / Dimensional range	PED category
Butterfly valves	Wafer type butterfly valves Wafer type butterfly valves Lug type butterfly valves Lug type butterfly valves	PN10 / Up to DN 600 PN16 / Up to DN 600 PN10 / Up to DN 600 PN16 / Up to DN 600	Up to II

Sites covered by this certificate

Site name	Site Address	Monitored by	Date	Report ref
Valvorobica Industriale S.p.A.	Via Giovanni Falcone, 2 - 24050 Zanica BG-Italy	Milan - Italy	06 December, 2017	12100282-20171206-MRG-RC-PED Mod. C2

Applications/limitations

Body material and min/max allowable temperature:

- EN 1563 EN-GJS-400-15 -10 °C to 200 °C;
- EN 1563 EN-GJS-400-18 -10 °C to 200 °C.

Temperature limitations:

- For butterfly valves with NBR seal max. design temperature shall be 80 °C;
- For butterfly valves with EPDM seal max. design temperature shall be 130 °C;
- For butterfly valves with FKM seal max. design temperature shall be 200 °C;
- Fluids: Group 2 liquids in general and a restricted number of group 1 toxic liquids as specified in the technical file.

Terms and conditions for the certificate

Valid terms and conditions are found in the DNV GL's PED Certification Rules

END OF CERTIFICATE